

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No. F.6/DFS/MS/School/2023/SZ/ 201

Dated: 21/03/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **St. Paul's School** at C-3, Safdarjung Development Area, New Delhi 110016 comprised of Basement, ground plus three upper floors owned/occupied by St. Paul's School was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2017/SZ/1542 Dt. 27/10/2017. The said premises was re-inspected by officer concerned of this department on 14/03/2023 in presence of Mr. Thomas P.T (Admin) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No 262-362 dated 17/01/2005 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "Educational Building Group - B" with effect from 21/03/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 21/03-2023 at New Delhi by

  
**ATUL GARG  
DIRECTOR  
DELHI FIRE SERVICE**

Copy to:-

1. The Principal, St. Paul's School at C-3, Safdarjung Development Area, New Delhi 110016.
2. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept unlocked and free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of BBL /NBC Part- IV.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."